

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

PROSOCO, Inc.

3741 Greenway Circle, Lawrence, KS, United States

For the following product(s):

Concrete Floor Finishes:

Consolideck GemTone™ Stain, Consolideck® LS/CS®, Consolideck® Blended Densifier, Consolideck® ColorHard, Consolideck® Concrete Protector SB, Consolideck® Concrete Protector WB, Consolideck® Grind-N-Fill, Consolideck® GuardEXT, Consolideck® LS®, Consolideck® LSGuard®, Consolideck® PolishGuard

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the school classroom, private office, and single-family residence parameters when modeled as flooring. Also, conforms to the SCAQMD Rule 1113 – Paints & Coatings (June 2011), or CARB SCM 2007, as applicable; European Decopaint Directive (2004/42/EC); Canadian VOC Concentration Limits for Architectural Coatings; Hong Kong Air Pollution Control (VOC) Regulation.

Average Product Application Amount: 191.4 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-IAQ-01606

Valid from: January 1, 2021 to December 31, 2021



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President

SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA